



PfB Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows
 Rollläden · shutters
 Türen + Tore · doors
 Fassaden · curtain walling
 Baubeschläge · building hardware

TEST CERTIFICATE NO. 13/12-A422-Z4

Version 1.en

Sound Insulation calculation according EN 14351-1 : 2006 + A1 : 2010 "Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets without resistance to fire and/or smoke leakage characteristics"

Applicant Kompen PVC Yapı ve İnşaat Malzemeleri Sanayi ve Ticaret A.Ş.
 Istanbul yolu 45. Km.Ladik Mevkii
 Sarayönü - Konya 42435

Product type Inward opening tilt and turn single casements window,PVC, double glazing

Product name Fensterbau 3600


Hardware GU

Sealing TPV

Glazing 4-12-4 (20 mm) Double glazing, air infill

Dimension Total outside dimensions (W x H) max. 900 mm x 2000 mm

Classification According to test report No. 13/12-A422-B3 from April 29, 2014:



Size of Specimen	Double glazing	4 - (6-14) - 4
Area ≤ 2,7 m ²	R _w (C; C _{tr}) dB	32 (-1;-5)
2,7 m ² ≤ Area ≤ 3,6 m ²	R _w (C; C _{tr}) dB	31 (-1;-5)
3,6 m ² ≤ Area ≤ 4,6 m ²	R _w (C; C _{tr}) dB	30 (-1;-5)
Area > 4,6 m ²	R _w (C; C _{tr}) dB	29 (-1;-5)

Validity Period of validity of EN 14351-1 : 2006 + A1 : 2010

Dipl. Ing. (FH) Rüdiger Müller
 Head of Institute



M.Eng.Dipl.-Ing. (FH) Eric Winter
 Responsible Official

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
 AG Traunstein HRA 8871
 Lackermannweg 24, 83071 Stephanskirchen
 phG PfB Verwaltungs GmbH
 Geschäftsführer: Matthias Demmel, Rüdiger Müller
 AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 674947 0
 Telefax +49 (0) 80 36 / 674947 28
 www.pfb-rosenheim.de
 info@pfb-rosenheim.de

Sparkasse Rosenheim-Bad Aibling
 IBAN: DE88 7115 0000 0500 5567 41
 SWIFT-BIC: BYLADEM1ROS
 Steuer-Nr.: 156/172/13009
 USt-IdNr.: DE245353602

